



- NOTES:
1. 4-STAGE REVERSE OSMOSIS SYSTEM WITH 75 GALLON PER DAY OUTPUT. STAGED FILTRATION INCLUDES 5.0 MICRON SEDIMENT FILTER, GAC CARTRIDGE, 1.0 MICRON PREFILTER, AND R.O. MEMBRANE T.F.C.
  2. 14 GALLON BLADDER TANK WITH 8 GALLON DRAW DOWN CAPACITY AT 40 PSI.
  3. 3/8" TUBE INLET FOR R.O. PRETREATMENT.
  4. FLUSH GAC FOR FINE RINSE BEFORE RO CONNECTION.
  5. FLUSH RO PRESERVATIVE FROM RO MEMBRANE AND TANK BEFORE COMMISSIONING.
  6. ARIES HP LOOP IS 110 VAC/60 HZ

THIS DRAWING CONTAINS PROPRIETARY INFORMATION. ANY USE OF THIS DRAWING OR INFORMATION CONTAINED HEREIN FOR OTHER THAN THE PURPOSE FOR WHICH THIS DRAWING IS FURNISHED IS FORBIDDEN.		ARIES FILTERWORKS WEST BERLIN, NJ (856) 768-9600		
		TITLE REVERSE OSMOSIS SYSTEM WITH STORAGE AND DEIONIZATION POLISHING		
CUSTOMER:	SIZE	DWN: JJB	DWG NO.	REV A
LOCATION:		APVD:	062806A-PID	
	SCALE NONE	DATE 4 MAY 04	SHEET 1 OF 1	